



230003

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Donald Zenz ADDRESS 1330 East St. Sparks Nev.
4200 Wild Horse Road Reno

2. LOCATION SE 1/4 SW 1/4 Sec. 22 T. 22 N/S R. 21 E. Washoe County
PERMIT NO. APN 077-158-14 Palomino V. Unit 1 23-2-1-12

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	44	
Coarse sand		44	73	
Clay	24	73	101	
Sand & fine gravel		101	104	
Clay		104	149	
Sand & gravel	155	149	166	
Clay		166	189	
Gravel (fine)		189	205	
Gravel (coarse)	215	205	227	
Sand		227	233	
Sand & gravel	239	233	268	
Clay		268	270	
Gravel	278	270	294	
Clay		294	296	
Gravel		296	300	

8. WELL CONSTRUCTION
Diameter hole 8 5/8" o.d. inches Total depth 300 feet
Casing record.....
Weight per foot 17 Thickness 188
Diameter 8 5/8" o.d. inches From 0 feet To 300 feet
.....inchesfeetfeet
.....inchesfeetfeet
.....inchesfeetfeet
.....inchesfeetfeet
Surface seal: Yes No Type Cement
Depth of seal 60 feet
Gravel packed: Yes No
Gravel packed from 60 feet to 300 feet
Perforations:
Type perforation factory sawed
Size perforation 3/32 x 3/4 round
From 154 feet to 174 feet
From 220 feet to 300 feet
Fromfeet tofeet
Fromfeet tofeet
Fromfeet tofeet

Date started 11/8 1978
Date completed 11/9 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M. 80 to 100
Water temperature cold F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
Name Paul Williams
Address 275 Courtney Lane Reno
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 11/8/78

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours