WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19200
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Marion Estates MDB & M ADDRESS Gardnerville Nevada.

2. LOCATION ¼ ¼ Sec. 20 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Lot #2 - Corner of Verde & Rohn - 1 Blackwest.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Broken rock and Clay -		0	20	20
Hard packed grave rim sand		20	35	15
Cobble stones Coarse sand Hard packed		35	70	35
Brown Hard packed Coarse sand - with black Cobble -		70	85	15
First Water at 30 feet raised to 20				
				85

Date started Dec 9, 1978
Date completed Dec 13, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 85 feet
Casing record
Weight per foot - Thickness 185

Diameter	From	To
6 5/8 inches	0 feet	85 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 ft feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation 3/32 x 3 Factory
Size perforation
From 66 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M.
Water temperature 56 ° F. Quality good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin W Graham
Address Gardnerville Nev.
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A. W. Graham
Date Dec 13 - 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471