

OFFICE USE ONLY
 Log No. 19225
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pyramid Lake Indian Housing ADDRESS Wadsworth, Nevada
House for Elmira Copeland - W-28

2. LOCATION 24 1/4 Sec. 15 T. 21 N/S R. 24 E. Washoe County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and gravel		0	30	30
Blue clay		30	50	20
Clay, sand and gravel		50	75	25
Red clay.		75	90	15
Sand & Gravel		90	110	20
Red Clay		110	117	7
Sand		117	140	23
Red Clay		140	144	4

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 144 feet
 Casing record 6 5/8
 Weight per foot _____ Thickness 138

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>144</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 30' feet
 Gravel packed: Yes No
 Gravel packed from 30 feet to 144 feet
 Perforations:
 Type perforation Mill slot
 Size perforation 3/32 x 3 1/2 "
 From 104 feet to 144 feet
 From _____ feet to _____ feet

Date started November 14, 1978
 Date completed November 17, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 1' Feet below land surface
 Flow 60 G.P.M.
 Water temperature Cold ° F. Quality Clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name The Water Development Corporation
 Address 205 B. Cal Lane, Sparks, Nevada
 Nevada contractor's license number 12832
 Nevada driller's license number 900
 Signed Robert J. Foster (wa)
 Date November 30, 1978

BAILER TEST

G.P.M.	Draw down	feet	hours