

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Roy Luskey ADDRESS 301 Gentry Way Reno NV 89502

2. LOCATION  $\frac{1}{4}$  Sec 6 T 16 N/S R 20 E Washoe County  
 PERMIT NO. 3240 Douglas Dr - Washoe Farms

3. TYPE OF WORK: New Well  Recondition  Deepen  Other   
 4. PROPOSED USE: Domestic  Irrigation  Test  Municipal  Industrial  Stock   
 5. TYPE WELL: Cable  Rotary  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	32	32
SAND & GRAVEL X		32	33	1
SANDY CLAY		33	67	34
SAND & GRAVEL X		67	70	3
SANDY CLAY		70	86	16
SAND & GRAVEL X		86	94	8
SANDY CLAY		94	98	4
SAND & GRAVEL X		98	104	6
SANDY CLAY		104	106	2

8. 12" WELL CONSTRUCTION  
 Diameter hole 12 inches Total depth 106 feet  
 Casing record 8 3/8  
 Weight per foot 16.9 Thickness 188  
 Diameter From To  
8 inches 0 feet 106 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Chloride  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 3 x 3/32  
 From 83 feet to 103 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-5-78, 19\_\_\_\_  
 Date completed 12-8-78, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 25 Draw down 25 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level \_\_\_\_\_ Feet below land surface 20  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 66 F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.M. Blair  
 Address Box 353 Dayton NV 89503  
 Nevada contractor's license number 10950  
 Nevada driller's license number 757  
 Signed Charles F. Blair  
 Date 12/15/78