WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19264
Permit No. 35554
Basin

1. OWNER Bob Weise ADDRESS Old 395

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 16 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
DG + Clay Streaks		8	50	42
Same - More Clay	*	50	95	45
Lg. DG sand + clay streaks	*	95	210	115
Same - (now showing iron)	*	210	230	20
Lg. (½) Dg sand + clay traces.	*	210	300	90
Blue clay		300	302	2

Date started Aug. 18 1978
Date completed Dec. 21 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
—	310	54'8"	12

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 468 feet
Casing record 302' x 8"
Weight per foot Thickness 188

Diameter	From	To
8 inches	feet	302 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 302 feet

Perforations:
Type perforation factory milled
Size perforation 3/32
From 60 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 11 Feet below land surface
Flow — G.P.M. 300 +
Water temperature 61 °F. Quality [illegible]

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co.
Address Rt. 3, Box 47 A, Susanville
Nevada contractor's license number 4739 A
Nevada driller's license number 794
Signed Jim V. Enloe
Date Jan. 5, 1979

USE ADDITIONAL SHEETS IF NECESSARY
5471