

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Rilite Aggregate Co. ADDRESS P.O. Box 5665
Reno, Nevada 89510

2. LOCATION SW 1/4 NW 1/4 Sec. 23 T. 18 S R. 20 E Washoe County
PERMIT NO. 36392 35499

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill material		0	20	20
White to grey material loose - large chips		20		
As above - also red chips still loose		20	35	15
White to grey to tan in color - slower drlg.		35	65	30
As above but more loose probably water bearing		65	80	15
White to grey w/smaller chips - more granular-slower drlg w/ some fractured areas		80	100	20
		100	115	15
TEST HOLE: As above but much harder		115	147	32

8. WELL CONSTRUCTION
Diameter hole 20 inches Total depth 115 feet
Casing record 0-115 x 12 3/4 OD
Weight per foot 33.38 Thickness .250

Diameter	From	To
<u>20</u> inches	<u>0</u> feet	<u>115</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement Slurry
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 115 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/16 x 3"

From	feet to	feet
<u>60</u>	<u>102</u>
.....
.....
.....
.....

Date started 11-11, 1978
Date completed 1-03, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>421 GPM @ 80'</u>	<u>depth after 8 hours</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
Static water level 65 Feet below land surface
Flow..... G.P.M.
Water temperature 113 °F. Quality Test in progress

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404 Sparks, Nevada 89431
Nevada contractor's license number 9767
Nevada driller's license number 493

Signed W.L. McDonald
Date 1-4-79