WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19362
Permit No.
Basin

1. OWNER ED QUEILHE ADDRESS [redacted] BADGER DR. SILVER
KNOLLS RANCH ESTATES APN 86-174-04

2. LOCATION ¼ ¼ Sec. 25 T. 21 N/S R. 18 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTS & SANDS		0	46	46
CLAY		46	62	16
SAND		62	66	4
SANDY CLAY		66	70	4
CLAY		70	73	3
SAND		73	86	13
CLAY		86	90	4
SANDY CLAY		90	96	6
CLAY		96	105	9
BR. SAND	—	105	110	5
SANDY CLAY		110	122	12
SAND		122	130	8
SANDY CLAY		130	142	12
BR. SAND	—	142	160	18
CLAY		160	165	5

Date started 11/2, 19 78
Date completed 11/6, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 165' feet
Casing record 8"
Weight per foot Thickness .188

Diameter	From	To
8" inches	0 feet	165 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 165' feet

Perforations:
Type perforation TORCH
Size perforation 3/16" By 8"
From 70 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FLOYD SUCHTA
Address 2465 ROSEMARY DR.
Nevada contractor's license number 14508
Nevada driller's license number 1028
Signed [signature]
Date 11/6/78

USE ADDITIONAL SHEETS IF NECESSARY

5471