

OFFICE USE ONLY
 Log No. 19376
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER PHILIP M. ALLOU AMERICAN INC. ADDRESS Box 1003
427 ELKO, NV 89801
 2. LOCATION SE 1/4 SE 1/4 Sec. 2 T. (24) N/S R. 63 E. ELKO County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aluminum		0	16	16
Clay		16	85	69
GRAVEL	✓	85	92	7
Pyroclastic sediment with thin streaks of gravel. All sand & gravel streaks water bearing	✓	92	358	266
GRAVEL	✓	358	367	9
Pyroclastics w/sand & gravel streaks	✓	367	445	78
GRAVEL	✓	445	462	17
T.D. 465				

8. WELL CONSTRUCTION

Diameter hole 1.0 inches Total depth 465 feet
 Casing record 4.73 PL 8 7/8
 Weight per foot 16.94 Thickness 188

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Clay in Pipe
 Depth of seal 16 ft. feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Mill slat
 Size perforation 1/4" x 3"
 From 9.5 feet to 11.5 feet
 From 18.5 feet to 46.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 10/13 1978
 Date completed 12/13 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 56 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING CO.
 Address 203 PINE, ELKO, NV 89801
 Nevada contractor's license number 10019
 Nevada driller's license number 632
 Signed Jamie V Muth
 Date 1/18/79