WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19472
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

33CCAB1

9

1. OWNER Jack Bell ADDRESS 5855 Green Valley Rd
Palmer Valley

2. LOCATION ~~NW~~ SW ¼ SW ¼ Sec. 33 T. 27N (N/S) R. 21 E. Washoe County
PERMIT NO. ADD 077-350-11

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/ gravel & Boldr		1	174	
Gravel w/ Boldr		174	191	
Sandy Clay w/ Boldr		191	200	
Fractured Rock	x	200	218	

See Log 27412 for cleaning

Date started 2-5, 1979
Date completed 2-26, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 12 Draw down 5 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 218 feet
Casing record 6" 10 gage
Weight per foot 10 gage Thickness

Diameter	From	To
6" Blank inches	+1 feet	158 feet
6" Perf inches	158 feet	178 feet
6" Blank inches	178 feet	198 feet
6" Perf inches	198 feet	218 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 51' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Vert Sawed
Size perforation 3/32 x 2"
From 158 feet to 178 feet
From 198 feet to 218 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 7 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality G

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles E Robertson
Address 1718 Verbena Way Sparks Nev
Nevada contractor's license number
Nevada driller's license number 1042
Signed Charles E Robertson
Date 3-6-79

USE ADDITIONAL SHEETS IF NECESSARY

5471