WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19526
Permit No. 35277-8
Basin 8-103

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Carson City, Public Works Dept. ADDRESS Well Located on the Adderson Ranch off 5th St.

2. LOCATION NE ¼ SW ¼ Sec. 14 T. 15 (N)S R. 20 E. Carson City County
PERMIT NO. 51903, 51901, 51879

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
Alt. layers, Sand grav. + clay	*	8	45	37
Coarse Sand + grav.	*	45	68	23
Clay		68	81	13
Sand, grav. + clay layers	*	81	93	12
Coarse Sand + grav.	*	93	123	30
Sand, grav. + traces of clay	*	123	138	15
Coarse sand, grav. + thin clay layers	*	138	168	30
Sand, grav. + cobbles/ clay layers	*	168	183	15
Sandy Clay (sticky)		183	288	105
Boulders in Clay		288	316	28
Hard gray rock		316	325	59

Well #25

Carson River Induction Well

Date started Nov. 7, 19 78
Date completed JAN 15, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	800	49	60

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 32"x70', 22"x180 inches Total depth 195 feet
Casing record 70' x 24", 195' x 12"
Weight per foot ..... Thickness 250

Diameter	From	To
24", surface seal inches	0 feet	70 feet
12 3/4 inches	+1 feet	195 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 70 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 70 feet to 195 feet

Perforations:
Type perforation Mill Slot + Louvers
Size perforation 1/8
From Louver 80 feet to 170 feet
From 1/8 Mill 170 feet to 190 feet
From 5' Blank on Bottom feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 Feet below land surface
Flow G.P.M. 800
Water temperature 62 °F. Quality —

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co.
Address Rt. 3, Box 47A
Nevada contractor's license number 4739 A
Nevada driller's license number 249
Signed [signature]
Date 3/28/79

USE ADDITIONAL SHEETS IF NECESSARY

5471