

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER WILLIAM L. WARDRUP ADDRESS 1070 - 5 Briarwood Drive Sparks Nev.  
440 Alamosa Spanish Springs Phone 76-290-09  
 2. LOCATION 1/4 1/4 Sec. 12 T. 21 N 20 E. Washoe County  
 PERMIT NO. Let 12-1-68

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	2	2
brn DG med loose		2	11	9
brn DG hard		11	98	87
grey granite med/hard		98	196	98
" " fract broken		196	214	18
brn rock med hard		214	239	25
green granite med hard				
w/some fract.		239	354	115
black rock med hard				
w/fract		354	395	41
blue clay w/blue rock	x	395	455	60
light blue green				
granite med loose	xx	455	500	45

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 500 feet  
 Casing record 500  
 Weight per foot \_\_\_\_\_ Thickness 156  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>500</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 ft. \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 500 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 310 feet to 330 feet  
 From 370 feet to 410 feet  
 From 434 feet to 454 feet  
 From 474 feet to 494 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/8/79, 19\_\_\_\_  
 Date completed 3/14/79, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 320 Feet below land surface  
 Flow 12 G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING INC.  
 Address P. O. Box 12370 Reno, Nev. 89510  
 Nevada contractor's license number 14043  
 Nevada driller's license number 812  
 Signed Frank Padilla  
 Date 3-27-79