WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19696
Permit No.
Basin

1. OWNER MR NICHOLAS STOLO ADDRESS 7500 Rocky Point Trl. Reno Nev.

7500 Rocky Point Trl Golden Valley

2. LOCATION ¼ ¼ Sec. 3 T. 20 N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	4	4
brn. DG med hard		4	53	49
gray granite hard		53	168	115
brn DG med hard		168	210	42
blue granite hard		210	226	16
blue granite hard & fract.	x	226	275	49

Date started 4/23/79, 19
Date completed 4/24/79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 275 feet
Casing record 275 ft.
Weight per foot Thickness 156

Diameter	From	To
6 5/8 inches	0 feet	275 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 275 feet

Perforations:
Type perforation factory sawed slot .
Size perforation 3/32 x 2½ x 6 around
From 226 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 155 Feet below land surface
Flow 50 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.

Address P.O. Box 12370 Reno, Nevada 89510

Nevada contractor's license number 14043

Nevada driller's license number #817

Signed Frank Padilla

Date 4-24-79

USE ADDITIONAL SHEETS IF NECESSARY

5471