WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19714
Permit No.
Basin

1. OWNER HARVEY SWANSON ADDRESS BOX 10268 ZEPHYR COVE NEV 89448

SEE NOTE 2. LOCATION SE ¼ NW ¼ Sec. 28 T. 26 N (N) S R. 18 E. WASHOE County
PERMIT NO. 720 PARCEL # 74-062-47

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [X] Rotary [ ] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
HARD PAN		4	15	12
BOLDERS		16	18	3
BROWN CLAY + SAND		19	47	29
GREY CLAY + SAND	WATER	48	55	8
GREEN CLAY		56	62	7
GREY CLAY + BLACK SAND		63	76	14
" " + GRAVEL	WATER	77	83	7
" " + BLK SAND	WATER	84	94	11
HARD GREY CLAY		95	99	5

LOCATION NOTE:

COMMENCING AT THE SE CORNER of SAID SEC. 28 thence along the Easterly LINE of said SEC. 28 N 0°52'03" WEST 654.00 ft. to the TRUE POINT of beginning thence N 89°51'14" W 674.97 ft. thence N 0°08'46" E 654.00 ft. thence S 89°51'14" E 663.22 ft. to a point in the East Line of said Sec. 28 thence along said East Line of Sec. 28 South 0°52'03" E 654.10 ft. to the Point of Beginning

Date started APRIL 10, 1979
Date completed APRIL 20, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 11 Draw down 5 feet 3/4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" 10"-58' TO 99' inches Total depth 99 feet
Casing record 6" TO BOTTOM
Weight per foot 10 lbs Thickness .156"

Diameter	From	To
6" inches	0 feet	99 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type GROUT
Depth of seal 50 FT. feet
Gravel packed: Yes [ ] No [X]
Gravel packed from feet to feet

Perforations:
Type perforation SLOT IN ROW
Size perforation 1/16"
From 49 feet to 59 feet
From 79 feet to 99 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 FT. Feet below land surface
Flow 11 G.P.M.
Water temperature NORMAL F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Hamilton FOR SUCHTA WELL DRILLING
Address SPARKS, NEV.
Nevada contractor's license number # 19508
Nevada driller's license number # 1023
Signed Tim Hamilton
Date April 21, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471