

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 19718
 Permit No.
 Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Carl Potetz ADDRESS 2861 Chavez Dr.
2425 Warrior Ln. Reno, Nevada 89502
 2. LOCATION $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 17 T. 19N R. 18E Washoe County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown DG & boulders, coarse		0	65	65
Blackish sands coarse		65	79	14
Brown, multi colors rock coarse		79	88	9
Brown gray boulders, sand, clay 1'-fine		88	94	6
Brown, black clays sands rock med.	x	94	128	34
Blue, black, gray rock clays, med	x	128	158	30
Gray blue rock clays, med fine	x	158	175	17

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 175 feet
 Casing record 5" 6.96"
 Weight per foot 6.578 12.89 Thickness 10 ga.

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>88</u> feet
<u>5</u> inches	<u>88</u> feet	<u>175</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from feet to feet
 Perforations:
 Type perforation Factory mill slot
 Size perforation 3/32
 From 88 feet to 175 feet
 From feet to feet
 From feet to feet
 From feet to feet

9. WATER LEVEL
 Static water level 7.5 feet below land surface
 Flow G.P.M.
 Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404 Sparks, Nevada 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805

Signed T. Betika by W.L. McDonald
 Tony Betika by W.L. McDonald
 Date April 16, 1979

Date started October 9, 1978
 Date completed April 13, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	<u>8.5 GPM @ 170' depth</u>		

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours