WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 19774
Permit No.
Basin

1. OWNER E.J. Primm ADDRESS c/o Whiskey Pete's Casino P.O. Box 128 Jean, Nevada 89019

2. LOCATION 1000' North of Whiskey Pete's Casino SE ¼ NE ¼ Sec. 9 T 27-S N/S R 57 E Clark County

PERMIT NO. 35618

3. TYPE OF WORK
New Well [X] Reconditioned [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Test [X]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & gravel		0	2	2
Limestone		2	35	33
Red clay		35	40	5
Gray clay		40	50	10
Red clay w/ limestone		50	75	25
Gray clay		75	80	5
Red clay		80	85	5
Red clay & gravel		85	125	40
Gray & red clay		125	165	40
Clay & gravel		165	175	10
Limestone		175	201	26
Clay		201	225	24
Clay w/ strks of gravel		225	245	20
Red clay & gravel		245	255	10
Hard limestone		255	257	2
Clay & gravel		257	330	73
Red clay		330	345	15
Red clay & gravel		345	395	50

RECEIVED
APR 18 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started January 18, 1979
Date completed February 2, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter bo[redacted] 13 3/4" - 265' inches, Total depth 395 feet
Casing record 9 7/8" - 140'
Weight per foot Thickness

Diameter		From		To	
10	inches	+1	feet	265	feet
8 5/8	inches	265	feet	395	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50' & from 255 - 265 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from feet to feet

Perforations:
Type perforation Saw cut
Size perforation 5/32 x 3"
From 275 feet to 395 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC.
Address 3215 Cinder Lane Las Vegas, Nevada 89103
Nevada contractor's license number 4286A
Nevada driller's license number 581
Signed [signature]
Date February 5, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471