

WELL DRILLERS REPORT

Please complete this form in its entirety



40001

1. OWNER Johnson Development Corp. ADDRESS P.O. Box 116
Fernley, Nevada

2. LOCATION SW 1/4 SW 1/4 Sec. 9 T. 20 N/S R. 25 E Lyon County
 PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	22	
Brittle Brown clay		22	51	
Soft brown clay		51	63	
Gray clay		63	110	
Brown brittle clay		110	117	
Coarse sand		117	123	
Cemented sand & brown clay		123	127	
Gray clay		127	165	
Gravel		165	190	
Sand		190	195	
Blue brittle clay		195	210	
Gravel		210	213	
Blue clay		213	230	
Gravel		230	249	
Gray clay		249	254	
Coarse sand & gravel		254	273	
Brown clay & cemented sand		273	275	
Gravel & coarse sand		275	281	
Yellow clay		281	285	
Coarse sand, gravel, rock		285	340	
Coarse sand, pea rock with brown clay		340	343	

8. WELL CONSTRUCTION

Diameter hole 24 inches Total depth 343 feet
 Casing record 16"
 Weight per foot 44 lbs. Thickness 1/4

Diameter	From	To
<u>16</u> inches	<u>0</u> feet	<u>343</u> feet

Surface seal: Yes No Type.....
 Depth of seal 265' feet
 Gravel packed: Yes No
 Gravel packed from 265 feet to 343 feet

Perforations:
 Type perforation Louwer
 Size perforation 1/8
 From 295 feet to 343 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started....., 19.....
 Date completed....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level..... Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality.....


10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name The Water Development Corp.
 Address 205 Cal Lane B., Sparks, Nev.
 Nevada contractor's license number 12852
 Nevada driller's license number 79-3
 Signed [Signature]
 Date 5/7/79

BAILER TEST

G.P.M.	Draw down	feet	hours



1370 MAY 15 AM 9 27