WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1993
Permit No.
Basin 88

1. OWNER FRONTIER INC. ADDRESS 335 EAST 6th STREET
CAL ROBINSON ASSOC. RENO, NEVADA 89505
Well site: 15890 Caswell Parcel # 2

2. LOCATION SE¼SW ¼ SW¼ SE ¼ Sec. 34 T. 18 N/S R. 19 E. Washoe County
PERMIT NO. MDBM

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite boulders & decomposed granite		0	100	100
clay & boulders	XX	100	201	101

Date started March 14, 19 79
Date completed March 20, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 130 feet 7 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 201 feet
Casing record 8 5/8" od x 188 wall
Weight per foot 16.94 Thickness

Diameter	From	To
12¼ inches	0 feet	201 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 70 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 70 feet to 201 feet

Perforations:
Type perforation 3" x 1/8" Milled
Size perforation
From 141 feet to 201 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 Feet below land surface
Flow G.P.M.
Water temperature 59 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY, INC.
Address 1500 EAST RANGER ROAD RENO, NV 89506
Nevada contractor's license number 7462A
Nevada driller's license number 615
Signed W. L. Doyle
Date March 30, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471