WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19940
Permit No.
Basin

1. OWNER DONALD W. DEANE ADDRESS 11130 HEARTPINE RENO, NEVADA 89506

2. LOCATION S ½ ¼ ¼ Sec. 23 T. 21 N/S R. 19 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
decomposed granite		0	65	65
decomposed granite with streaks of clay		65	123	58
decomposed granite		123	128	5
granite		128	150	12
fractured rock		150	160	10

Date started April 6, 19 79
Date completed April 10, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 150 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record 8 5/8" od x 188 wall
Weight per foot 16.94 Thickness

Diameter	From	To
12¼ inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 160 feet

Perforations:
Type perforation Milled
Size perforation 3" x 1/8"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface
Flow G.P.M.
Water temperature 58 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY
Address 1500 EASTM RANGER RD RENO, NV 89506
Nevada contractor's license number 7462A
Nevada driller's license number 615
Signed [illegible]
Date April 23, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471