WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19976
Permit No.
Basin 088

1. OWNER Robert ~~Wilhelm~~ Parcel #045-533-12 ok ADDRESS 5485 HAZELWOOD CIRCLE Incline, Nev. LOT #257 GALENA TERRACE UNIT #2

2. LOCATION Portion ¼ ~~NE NW~~ SW, NW Sec. 2 T. 17 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0 | 3 | 3 |
| DG with Boulders and slight traces of Clay | | 3 | 141 | 138 |
| Boulder | | 141 | 148 | 7 |
| Clay with small gravel & boulders | 160 | 148 | 200 | 52 |
| Water partials | 195 | | | |
| T.D. 200 | | | | |
| deepened by log # 80496 | | | | |
| plugged by log # 112456 | | | | |
| 39.371180° N NAD27 | | | | |
| 119.822790° W | | | | |

Date started 5-26, 1979
Date completed 5-29, 1979

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Blew for ½ hrs with 180 lbs. air 50 cfm | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
6 5/8 x 50'
Diameter hole 8 3/4 inches Total depth 200 feet
Casing record 6 5/8
Weight per foot 8.68 Thickness .125

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 200 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation L 32 - Factory
Size perforation X3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 54 Feet below land surface 146
Flow G.P.M. 10
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling + Well Service
Address 2255 Glendale ave Sparks
Nevada contractor's license number 15291
Nevada driller's license number 732
Signed [signature]
Date June 4, 1979

MMH (P)

USE ADDITIONAL SHEETS IF NECESSARY

5471