WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26014
Permit No.
Basin

1. OWNER Robt Chiolino ADDRESS 320 Coot Dr
New Washoe City

2. LOCATION NE ¼ SE ¼ Sec. 5 T. 16 N/S R. 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Dk Semi		0	160	160
Loose Loosly				
Cemented				
Well Required Dg	X	160	193	33
multi col				
T.D. 193				

Date started 6-7, 1979
Date completed 6-7, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow @ 160# PSI			for 35 min
to clean + Develop			
	-14	gpm	-

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10 5/4 - 50' WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 193 feet
Casing record 6 5/8
Weight per foot 9.29 Thickness 10 gum

Diameter	From	To
6 5/8 OD inches	+1 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 193 feet

Perforations:
Type perforation FACTORY
Size perforation 1/8 X 3
From 169 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 85 Feet below land surface
Flow G.P.M. 11
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Area 4 Drilling
Address 2255 Glendale Ave Sparks
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [signature]
Date 6-14-79

USE ADDITIONAL SHEETS IF NECESSARY

5471