

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Cam Solari ADDRESS 7803 Lakeside Dr.  
Parcel 13

2. LOCATION NE 1/4 5E 1/4 Sec. 2 T. 19 N. R. 19 E. WASHOE County  
 PERMIT NO.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	6	
CLAY		6	31	
SAND		31	45	
CLAY		45	52	
Clay + Sand		52	97	
SAND + Gravel		97	120	
CLAY		120	122	

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 120 feet  
 Casing record  
 Weight per foot Thickness 188  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>120</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 5.5 feet to 100 feet  
 Perforations:  
 Type perforation 3/2 Factory  
 Size perforation  
 From 80 feet to 120 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

9. WATER LEVEL  
 Static water level Feet below land surface  
 Flow YES G.P.M. 15  
 Water temperature ° F. Quality Good

Date started May 7, 1979  
 Date completed May 15, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>30</u>	<u>50</u>	<u>22.10</u>

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MEHAR P. HALL  
 Address 4000 STARK ST. Reno  
 Nevada contractor's license number 15170  
 Nevada driller's license number 1094  
 Signed Mehar P. Hall  
 Date 6-17-79

BAILER TEST  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours