WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20022
Permit No. 35653-52
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Arnold Meyer ADDRESS P.O. Box 1209 Winnemucca NV 89445

2. LOCATION ¼ ¼ Sec. 31 T. 38 N/S R. 32 E. Humboldt County
PERMIT NO. 27949 & 27950 35682 35683

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan colored topsoil - sandy		0	5	5
Multi-colored fine sands with silt		5	30	25
As above with some tan clay (5% ±)		30	85	55
Fine to coarse sands with silt and gravel to ¼" diameter some inconsistant clay lenses (3% or less)		85	150	65
Brown sandy clay (40%) with coarse sand lenses-maybe some water		150	185	35
Alternate streaks of yellow clay & coarse sands (fine gravels to ¼" diameter) multi-colored sands. Formation approx. 45% clay - inconsistantly water bearing		185	275	90
Fine to coarse sands with gravels to 3/8" diameter. Some clay lenses. Major water bearing zone		275	380	105

Date started April 11, 19 79
Date completed June 2, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Test by Owner (Driller would anticipate the well to produce approximately 2,000 GPM ± from a reasonable pumping depth)			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 380 feet
Casing record 0-380 x 16" OD
Weight per foot 42.05 Thickness .250

Diameter	From	To
inches	feet	feet
16 inches	0 feet	380 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 380 feet

Perforations:
Type perforation Factory mill slot
Size perforation .125
From 230 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 55 Feet below land surface
Flow G.P.M.
Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404 Sparks, Nevada 89431
Nevada contractor's license number 9767
Nevada driller's license number 953
Signed D. Cohen by W.L. McDonald
D. Cohen by W.L. McDonald
Date 6-18-79

USE ADDITIONAL SHEETS IF NECESSARY

5471