

OFFICE USE ONLY
 Log No. 20057
 Permit No. _____
 Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr. Pritchard ADDRESS 2956 Oregon Blvd. Lemon Valley, Nev.

Lot 8 Block 21, Heppner Subdivision # 3

2. LOCATION 1/4 1/4 Sec. 23 T. 21 N/S R. 17 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input checked="" type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburdden decomposed granite		0'	25'	25'
dry gravel		25'	50'	25'
fractured granite		50'	75'	25'
gravel and clay		75'	105'	30'
gravel and rock		105'	125'	20'
sand, rock water gravel		125'	169'	44'
gravel		169'	179'	10'
water and gravel		179'	205'	26'
		205'	230'	25'
Set pump at 160'				

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth _____ feet
 Casing record 230'
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6-5/8"</u> inches	<u>0</u> feet	<u>230'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50' feet to 230' feet

Perforations:
 Type perforation factory sawed slots
 Size perforation 3/32" X 2 1/2"
 From 170' feet to 230' feet
 From _____ feet to _____ feet

Date started 11-17-78, 19____
 Date completed 11-20-78, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 110' Feet below land surface
 Flow 15 G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
 Address 7310 ESTATES RD. RENO, NEVADA
 Nevada contractor's license number 6045
 Nevada driller's license number 1044
 Signed Matthew J. Kearney
 Date 11-22-78