WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20074
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Don Melvin ADDRESS Gardnerville, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. Spring Valley

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & clay		0	15	15
Broken rock				
Broken rock Clay boulders		15	55	40
Solid rock of brown and gray color Conglomerate		55	90	35
Gravel & clay		90	105	15
Sharp gravel, some clay		105	125	20
Solid rock Conglomerate		125	130	5
				130

Date started June 21, 1979
Date completed June 29, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 5 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10½ inches Total depth 130 feet
Casing record 19 8⅝ OD
Weight per foot 19 Thickness 188

Diameter	From	To
inches	feet	feet
8⅝ inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 + feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 85 feet to 110 feet

Perforations:
Type perforation 1/8 x 3 Factory
Size perforation 1/8 x 3
From feet to feet
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M.
Water temperature 50 °F. Quality Ex

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Andrew D. Graham
Address Gardnerville - Nevada
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A W Graham
Date June 30 - 79

USE ADDITIONAL SHEETS IF NECESSARY

5471