WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20087
Permit No.
Basin

1. OWNER Tom Anderson ADDRESS 400 Bunker Hill
Carson City, Nevada 89701
(Lot 17 Valley View Subdivision)

2. LOCATION SW ¼ SW ¼ Sec. 12 T. 14 N (N)S R. 19 E. Douglas County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 1 | 1 |
| Brown Clay & Gravel | | 1 | 42 | 41 |
| Gravel | | 42 | 58 | 16 |
| Brown Sandy Clay | | 58 | 74 | 16 |
| Clay & Gravel | | 74 | 116 | 42 |
| Firm Sandy Clay | | 116 | 134 | 18 |
| Gravel & Sand | ✓ | 134 | 146 | 12 |
| Gravel & Sand | ✓ | 146 | 161 | 15 |
| Brown Clay & Gravel | | 161 | 169 | 8 |
| Gravel & Sand | | 169 | 176 | 8 |
| Sandy Clay | | 176 | 184 | 8 |
| Tanish Brown Clay | | 184 | 192 | 8 |
| Brown Sandy Clay | | 192 | 213 | 21 |
| Sand & Gravel | ✓ | 213 | 217 | 4 |
| Pea Gravel | ✓ | 217 | 225 | 8 |
| Decomposed Granite | | 225 | 229 | 4 |

Date started April 24, 19 79
Date completed May 2, 19 79

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 12" to 50' WELL CONSTRUCTION
Diameter hole 8" inches Total depth 229' feet
Casing record
Weight per foot 16.94 Thickness .188

| Diameter | From | To |
|---|---|---|
| 8" inches | 0 feet | 229' feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 140 feet to 225' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 131' Feet below land surface —
Flow 15 to 20 G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Nevada Pump & Drilling Co., Inc
Address 6349 Hiway 50E C.C. Nev. 89701
Nevada contractor's license number 12236-A
Nevada driller's license number 662
Signed Jerry Bergstad
Date May 3, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471