

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Douglas Bailey ADDRESS 205 Mc Clellan New Washoe City  
 2. LOCATION N.E. 1/4 S.W. 1/4 Sec. 32 T. 17 N.S. R. 20 E. Washoe County  
 PERMIT NO. 885

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Sand & DG		0	55	55
DG + Quartz with a small amount of Clay - Brown		55	82	27
HARD DG WITH SMALL GRAVEL IN SPOTS		82	175	93

8. 10 3/8 - 50' WELL CONSTRUCTION  
 Diameter hole 8 3/4 inches Total depth 175 feet  
 Casing record 6 3/8  
 Weight per foot 8.68 Thickness 12.5  

Diameter	From	To
<u>6 3/8</u> inches	<u>0</u> feet	<u>175</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 5.0' feet  
 Gravel packed: Yes  No   
 Gravel packed from 5.0' feet to ..... feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 1/2  
 From 1.35 feet to 175 feet  
 From ..... feet to ..... feet

Date started 6-25-1979  
 Date completed 6-29-1979

9. WATER LEVEL  
 Static water level ..... Feet below land surface  
 Flow ..... G.P.M.  
 Water temperature cold °F. Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>blew well at 150# for 40 mins to clear develop</u>			

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE  
 Address 2255 Glendale ave  
 Nevada contractor's license number .....  
 Nevada driller's license number 1037  
 Signed Kurt Suelth  
 Date 6-29-79

BAILER TEST

G.P.M. ....	Draw down ..... feet	..... hours
G.P.M. ....	Draw down ..... feet	..... hours
G.P.M. ....	Draw down ..... feet	..... hours