WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20219
Permit No.
Basin

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER BOB FABRAZIO ADDRESS 3860 Tannenbaum Way Reno, Nevada 89509

Lot 41 Block G 21835 Adobe Rd. Virginia City Highlands (well Location)

2. LOCATION ¼ ¼ Sec. 32 T. 18 N/S R. 21 E. Storey County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| top soil | | 0 | 4 | 4 |
| brn sandy clay | | 4 | 18 | 14 |
| gray rock med hard | | 18 | 69 | 51 |
| blue rock hard | | 69 | 81 | 12 |
| blue rock hard fract. | x | 81 | 102 | 21 |
| blue rock w/clay layer | | 102 | 136 | 34 |
| Red rock med hard | | 136 | 172 | 36 |
| gray rock hard | | 172 | 211 | 39 |
| blue rock hard w/fract | x | 211 | 275 | 64 |

Date started 7/30/79, 19
Date completed 8/1/79, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 275 feet
Casing record 275 ft.
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 275 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 275 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 255 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 18 Feet below land surface
Flow 10 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.

Address P. O. Box 12370 Reno, Nevada 89510

Nevada contractor's license number 14043

Nevada driller's license number 8/17

Signed Frank Padilla

Date 8-2-79

USE ADDITIONAL SHEETS IF NECESSARY

5471