WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20224
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Steele Holman ADDRESS 39 West St. Yerington, NV 89447

2. LOCATION NW ¼ NE ¼ Sec. 27 T. 17 N N/S R. 23 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
clay & sand		2	4	2
coarse sand		4	20	16
clay		20	21	1
coarse sand		21	28	7
clay		28	95	67
clay el coarse sand		95	115	20
coarse sand, gravel few rock	X	115	132	17

Date started 7-31, 19 79
Date completed 8-5, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	40	4'	3 hrs.

BAILER TEST
G.P.M. 20 Draw down 2 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 5/8 inches Total depth 131 feet
Casing record
Weight per foot Thickness .156 .219

Diameter	From	To
8 5/8 inches	+1 feet	131 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 131 feet

Perforations:
Type perforation sawed
Size perforation 3/32 x 3" x 8 rows
From 111 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 54' Feet below land surface 53'
Flow G.P.M.
Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros. Drilling
Address 1162 N. Bybee Rd. Yerington, NV 89447
Nevada contractor's license number 15646
Nevada driller's license number 870
Signed Billy Ogden
Date 8-10-79

USE ADDITIONAL SHEETS IF NECESSARY

5471