WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

I

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20230
Permit No.
Basin

1. OWNER Tuscarora Associates ADDRESS Tuscarora, NV

2. LOCATION NW ¼ NE ¼ Sec. 3 T. 39 N/S R. 51 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lava (andesite)		0	40	40
Pyroclastic (andesite)		40	225	185
Rock & clay	minor	225	230	5
Pyroclastics		230	310	80
Silicified (w/straw & wood fragments) (?old mine fill?)		310	315	5
Rock & clay		315	425	110
Pyroclastics		425	450	

Abandoned
Left full of drilling mud — JM
Capped with steel plate

Date started 5/15 ~~5/31~~, 1979
Date completed 5/31, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 450 feet
Casing record 5' x 14
Weight per foot Thickness .250

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Abandoned

9. WATER LEVEL
Static water level 80 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality Poor

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Richard W. Mann for: Muth
Address Drilling Co. Elko
Nevada contractor's license number 10819
Nevada driller's license number 941
Signed James V Muth
Date 8/1/79

USE ADDITIONAL SHEETS IF NECESSARY

5471