

OFFICE USE ONLY
 Log No. 2029
 Permit No. 089
 Basin. 089

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Walter Bunch ADDRESS 7420 Franktown Rd
#1 CC, NV
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec 20 T. 16 N S 20 E Washoe County
 PERMIT NO. 7495 H 395 S

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black soil		0	4	4
Sandy clay		4	28	24
Sandy clay with x		28	45	17
Layers sand & clay		45	85	40
Brown g.		85	94	9
Red clay sand		94	150	56
Coarse gravel		150	161	11
Clay		161	163	2

8. WELL CONSTRUCTION
 Diameter hole 11 3/8 inches Total depth 163 feet
 Casing record 8 5/8
 Weight per foot 16.9 Thickness .88

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>163</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Rotary
 Size perforation 3 X 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Date started 7-12-79, 19_____
 Date completed 7-19-79, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 45 Feet below land surface
 Flow N2 G.P.M.
 Water temperature cold F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W. M. Blair
 Address Box 353 Dayton NV
 Nevada contractor's license number 10950
 Nevada driller's license number 1029
 Signed William A. Kinkel
 Date 8/10/79

BAILER TEST
 G.P.M. 20 Draw down 15 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours