WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20296
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Doug Cardwell ADDRESS Gardnerville - Nevada

2. LOCATION N½ NW ¼ SE ¼ NE ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Broken rock -		0	30	30
Clay sand gravel		30	80	50
Clay and Boulders -		80	120	40
Some water at 120 feet.		~~120~~	~~149~~	~~29~~
Solid Conglomerate Very hard.		120	149	29
Water at 142 Steam in hole				
				149

Date started Aug 30, 19 79
Date completed Sept 4, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 & 20 Draw down 25 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 149 feet
Casing record
Weight per foot 19 Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	149 feet
inches	feet	feet
6 5/8 slots inches	120 feet	149 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 + feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation 1/8 x 3 factory
Size perforation 1/8 x 3
From feet to feet
From 115 feet to 149 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M.
Water temperature 40 ° F. Quality Cs

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Curtis W. Graham
Address Gardnerville Nevada
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed C.W. Graham
Date Aug 5 - 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471