

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Emmett Harvey/Coronet Homes Inc ADDRESS 2100 Brooksboro Circle
4040 Odile Ct.
Reno, Nevada 89502
 2. LOCATION NE 1/4 SE 1/4 Sec. 11 T. 18N N/S R. 19 E. washoe County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill material		0	3	3
Yellow clay with boulders to 2' diameter		3	12	9
Fine to coarse sand with 2% silt and semi-rounded gravels to 1 1/2" diameter		12	40	28
As above with 8% boulders to 1' diameter and 5% cobbles to 6" diameter occasional yellow clay streak to 10" in thickness		40	105	65
15% cobbles to boulder size mixed with fine to coarse sand and approx. 3% silt		105	115	5
Fine to coarse silty sand		115	120	5
Fine to coarse sand with approx. 6% semi-rounded volcanic gravels to 3/4" dia. occasional cobble to 6" diameter (2%)	xx	120	138	18
Reddish brown clay, hard		138	141	3
Date started <u>August 21</u>				19.79
Date completed <u>August 24</u>				19.79

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 141 feet
 Casing record 0-141 x 6 5/8" OD
 Weight per foot 12.89 Thickness 1.88

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>141</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory Mill Slot
 Size perforation 1/8 x 2 1/2"
 From 109 feet to 141 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	17 GPM @ 125' depth		
	33 GPM @ 138' depth		

9. WATER LEVEL

Static water level 9.5 Feet below land surface
 Flow _____ G.P.M.
 Water temperature c.o.l.d. °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404 Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 493
 Signed W.L. McDonald
 W.L. McDonald
 Date August 24, 1979

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours