WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20387
Permit No. 34955
Basin WARM SPRGS VAL
34956

02CC DB

1. OWNER DR. DALE ADDRESS ANNIVERSARY RANCH & WINNEMUCCA RANCH ROAD
ASW Sec 2 T24-27

2. LOCATION SW ¼ SW ¼ Sec. 2 T. 22 N/S R. 20 E. WASHOE County
PERMIT NO. 34955 Rubenstein Unit 3 2-8-12

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine sand		0	30'	30'
decomposed granite		30	50'	20'
fine cemented brownish sand		50'	330'	280'
fine sand, gravel, water		330'	380'	50'
fine cemented, clay, sand		380'	400'	20'
set pump at 350'				

Date started 9-1-79, 19
Date completed 9-8-79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6-;58 inches Total depth 400' feet
Casing record
Weight per foot Thickness 156

Diameter	From	To
6-/58 inches	0 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32
From 338 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 125 Feet below land surface
Flow 20 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address P.O. BOX 624, SPARKS, NEVADA
Nevada contractor's license number 6045
Nevada driller's license number 1044
Signed M. Kearney
Date 9-15-79

USE ADDITIONAL SHEETS IF NECESSARY

5471