WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20390
Permit No.
Basin

1. OWNER LYNN TERRY/ HAZEL RYLAND ADDRESS ARROWHEAD DRIVE CARSON CITY, NEV.

2. LOCATION ¼ ¼ Sec. 5 T. 15 N/S R. 20 E. CARSON CITY County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine sand		0	25'	25'
decomposed granite		25'	75'	50'
decomposed granite, clay		75'	100'	25'
granite, sand, water		100'	120'	20'
med. size rock, granite		120'	150'	30'
gravel, rock , water		150'	182'	32'
Set pump at 160'				

Date started 8-15-79, 19
Date completed 8-18-79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6-1/58 inches Total depth 182' feet
Casing record
Weight per foot Thickness 156

Diameter	From	To
6-5/8" inches	0 feet	182' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 182 feet

Perforations:
Type perforation factory sawed slots
Size perforation 3/32
From 114 feet to 182 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35' Feet below land surface
Flow 15 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address P.O. Box 624, SPARKS, NEV. 89431
Nevada contractor's license number 6045
Nevada driller's license number 1044
Signed M. Kearney
Date 8-20-79

USE ADDITIONAL SHEETS IF NECESSARY

5471