WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20408
Permit No.
Basin

1. OWNER Rose Wilke ADDRESS 4001 Rewana Wy
Location of well at 4001 Rewana Wy
2. LOCATION SW ¼ NE ¼ Sec. 30 T. 19 N N/S R. 20 E. Washoe County
PERMIT NO. 1009

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/some sand		0	46	46
Sand (coarse) w/weathered rock + gravels to 2½"	X	46	57	11+
T.D. 57'				

Date started 10-12-, 1979
Date completed 10-12, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Blew @ ½ hr	270# to	psi for clean + develop
	Approx 18 GPM		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10¾ inches Total depth 57 feet
Casing record 6⅝ OD
Weight per foot Thickness .156

Diameter	From	To
6⅝ OD inches	+1 feet	57' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 57 feet

Perforations:
Type perforation ¼ X 3
Size perforation FALTORY
From 50 feet to 57 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 1½ Feet below land surface
Flow G.P.M.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling + Well Service
Address 2255 Glendale Ave.
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [signature]
Date 10-13-79

USE ADDITIONAL SHEETS IF NECESSARY

O-627