

OFFICE USE ONLY
Log No. 20419
Permit No. 35449
Basin 42958

JAMES HOLLAND
WELL DRILLERS REPORT
Please complete this form in its entirety

1. OWNER PAUL BARNES ADDRESS FLORIPITAN 4 VERDE LAS VEGAS

2. LOCATION LOT 2 SE SW-NW
S. 1/4 SE 1/4 Sec. 32 T. 19 N/S R. 60 E. CLARK County
PERMIT NO. 35449 42958

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light Cemented Gravel		0	40	40
BRN Clay + Gravel		40	76	36
COURSE GRAVEL		76	85	9
BRN CLAY + GRAVEL		85	240	155
GRAVEL - WATER	✓	240	251	11
GREY LIME		251	305	54
COURSE GRAVEL	✓	305	314	9
BRN SANDY CLAY + GRAVEL		314	350	36

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 350 feet
Casing record 8 5/8
Weight per foot 12.20 Thickness 10 GA.
Diameter 8 5/8 inches From 0 feet To 350 feet
Surface seal: Yes No Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes No
Perforations:
Type perforation TORCH
Size perforation 1/4 X 1/4 X 4 AROUND
From 230 feet to 350 feet

RECEIVED

MAY 2 1976
Div. of Water Resources
Branch Office - Las Vegas, Nev

Date started 10-1 1976
Date completed 10-18 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 36 Draw down 18 feet 1/2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

9. WATER LEVEL
Static water level 215 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN WATER WELL SERVICE
Address P.O. Box 15149 L.V., NEV. 89114
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed Frank B. Allen
Date 10-26-76