

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Richard Bailey ADDRESS 1300 Marietta Way
Sparks, Nevada 89431

2. LOCATION NW 1/4 NE 1/4 Sec. 21 T. 20 N/R. 20 E. Washoe County
 PERMIT NO. plat plan 8329203 - 36269 - 36270 - 36271

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil & clay w/s Rock</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>Clay w/s gravel</u>		<u>15</u>	<u>35</u>	<u>20</u>
<u>Clay with pebbles</u>		<u>35</u>	<u>70</u>	<u>40</u>
<u>Rock shell</u>		<u>70</u>	<u>83</u>	<u>13</u>
<u>Clay w/Rock & gravel</u>		<u>83</u>	<u>120</u>	<u>37</u>
<u>Clay & gravel streak</u>		<u>120</u>	<u>132</u>	<u>12</u>
<u>Rock shell</u>		<u>132</u>	<u>159</u>	<u>27</u>
<u>Gravel & clay streak</u>		<u>159</u>	<u>180</u>	<u>21</u>
<u>Clay w/s Rock</u>		<u>180</u>	<u>190</u>	<u>10</u>
<u>Rock broken basalt</u>		<u>190</u>	<u>210</u>	<u>20</u>

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 210 feet
 Casing record.....
 Weight per foot..... Thickness 188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>110</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 210 feet

Perforations:
 Type perforation Factory Slot
 Size perforation 1/8
 From 90 feet to 210 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL

Static water level..... Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality Good

Date started 4-24, 1979
 Date completed 4-28, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Brinkerhoff Pump & Drilling Co., Inc.
 Address P.O. Box 1026, Winnemucca, NV
 Nevada contractor's license number 12265B
 Nevada driller's license number 647

BAILER TEST

G.P.M.	Draw down	feet	hours

Signed [Signature]
 Date 4-28-79