WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20463
Permit No.
Basin

3rd Well

1. OWNER Louis A. Poole ADDRESS Box 327 Elko, 89801
Ryndon sub-division
2. LOCATION SE ¼ SE ¼ Sec. 36 T. 36 N/S R. 56 E. Elko County
PERMIT NO.

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☑ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	12	12
Gravel	Seep	12	13	1
Sandy clay		13	18	5
Gravel	✓	18	19	1
Sandy clay		19	90	71
Gravel	8gpm	90	92	2
Sandy clay		92	115	23
Clay with gravel streaks	HW	115	135	20
T.D. 135				

Date started 10/27, 1979
Date completed 11/3, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 70 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10-8 inches Total depth 135 feet
Casing record 136 ft 6 5/8
Weight per foot 12.92 Thickness .188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 135 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8" x 3" x 12/ft
From feet to feet
From 105 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mutt Drilling Co
Address 203 Pine, Elko
Nevada contractor's license number 10819
Nevada driller's license number 632
Signed James V. Mutt
Date 11/5/79

USE ADDITIONAL SHEETS IF NECESSARY

O-627