WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20471
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Warren Harding ADDRESS 140 Rainbow Dr Dayton, Nev 89403

2. LOCATION N1/2 S1/2 Sec. 27 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. Lot 140 Pinion at View

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Yellow Clay		6	40	34
Gravel & Sand		40	64	34
Rock & Clay		64	80	16
Clay		80	96	16
Hard Rock		96	126	30
Grey Clay		126	132	06

First Abandoned well & moved over ledge of red rock.

Date started 9-13-79, 19
Date completed 9-19-79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 10 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" 50' 8" 46' inches Total depth 132 feet
Casing record 6" 40' 8 5/8 & 6 5/8
Weight per foot 16.5 & 12.89 Thickness .188

Diameter	From	To
8 inches	0 feet	96 feet
6 inches	92 feet	132 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Bentonite
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 80 feet

Perforations:
Type perforation Factory
Size perforation 3 X 3/32
From 72 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 76 Feet below land surface
Flow G.P.M.
Water temperature Cold Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W M Blair
Address PO Box 353 Dayton Nev
Nevada contractor's license number 10950
Nevada driller's license number 963
Signed R O Farwell
Date 10/1/79

USE ADDITIONAL SHEETS IF NECESSARY

5471