

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Bob Rodrick ADDRESS 1257 Rawhide  
Las Vegas, Nev.  
 2. LOCATION  $\frac{1}{4}$  E  $\frac{1}{4}$  Sec. 26 T. 32 N/S R. 57 E Elko County  
 PERMIT NO. Pleasant Valley Lot 3 Block F

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Brown Sandy Clay</u>		<u>6</u>	<u>90</u>	<u>84</u>
<u>Limestone</u>		<u>90</u>	<u>92</u>	<u>2</u>
<u>Caving Sand</u>	<input checked="" type="checkbox"/>	<u>92</u>	<u>100</u>	<u>8</u>
<u>Brown Clay &amp; Stones</u>		<u>100</u>	<u>105</u>	<u>5</u>
<u>Caving Sand</u>	<input checked="" type="checkbox"/>	<u>105</u>	<u>115</u>	<u>10</u>
<u>Soft Sandy Clay</u>		<u>115</u>	<u>150</u>	<u>35</u>
<u>Sticky Brown Clay</u>		<u>150</u>	<u>160</u>	<u>10</u>

8. 12" 55' WELL CONSTRUCTION  
 Diameter hole 10.5" - 8" inches Total depth 160 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement Grout  
 Depth of seal 4' to 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory Cut  
 Size perforation 1/2 x 3  
 From 120 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-1, 1979  
 Date completed 10-8, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 30 Draw down 3 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 90 Feet below land surface.  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature Cool F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name O.M. Sullist Drilling Co  
 Address PO Box 41 - Elko, Nev 89801  
 Nevada contractor's license number 4796  
 Nevada driller's license number 115  
 Signed O.M. Sullist  
 Date 10-9-79