36055

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

29287

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20533
Permit No. 36054
Basin SPANISH SPGS

1. OWNER Spanish Springs Dev. Co. or Desert Spring Jim Patterson Owner. ADDRESS 7755 Pyramid Rd. Reno, Nev.

2. LOCATION ¼ ¼ Sec. 34 T. 21 N/S R. 20 E. Washoe County

PERMIT NO. 29286

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ ~~Other~~ Redrill ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ (Reverse)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy clay		0	23	
sand		23	31	
Clay		31	43	
sandy clay		41	55	
Clay		55	58	
sand	15	58	73	
fine gravel	4	73	77	
sand with clay				
streaks		77	186	
sandy clay		186	190	
sand	8	190	198	
sandy clay		198	199	
Clay		199	203	
D.C.		203	206	
sandy clay		206	208	
course sand	4	208	212	
sandy & clay streaks		212	216	
course sand	11	216	227	
Clay		227	246	
D.C.	7	246	253	
Clay		253	259	
sandy clay		259	266	
Clay		266	268	
sandy clay		268	271	
Clay		271	306	

Date started 11/18, 1929
Date completed 11/25, 1929

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 10" inches Total depth 306 feet
Casing record
Weight per foot 29 Thickness .250

Diameter	From	To
10 3/4 o.d. inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal Surface Pipe 51 feet
Gravel packed: Yes ☑ No ☐ Permanent pipe 55
Gravel packed from 55 feet to 306 feet

Perforations:
Type perforation Factory saw Cut
Size perforation 3/32 x 25
From 58 feet to 288 feet
From ~~[illegible]~~ feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 22 Feet below land surface
Flow G.P.M. Approx. 800
Water temperature Cold ° F. Quality Clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 South Patterson
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 11/26/79

USE ADDITIONAL SHEETS IF NECESSARY

5471