WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20535
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Floyd Lunkwitz ADDRESS Lower South Fork Waysack, Elko, NV 89801

Lower Ten Mile Ranch Area

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 33 N/S R. 55 E. Elko County

PERMIT NO.

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pyroclastic - tuff		0	95	95
Sand & gravel	✓	95	100	5
Pyroclastics (tuff & Chalcedony -		100	160	60
Gravel	✓	160	166	6
Clay (tuff)		166	175	9
T.D. 175				

Date started 11/5, 19 79
Date completed 11/12, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 1 feet
Casing record 176 Ft x 6 5/8
Weight per foot 12.92 Thickness .188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Portland Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation ½" x 3" x 12/ft.
Size perforation Mill slots.
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 25 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Amos Stockton Drilling Co.
For: [illegible] Pine Street
Address Elko, Nevada 89801

Nevada contractor's license number 10819

Nevada driller's license number Stockton 922

Signed James V. Muth (632)

Date 11/30/79

USE ADDITIONAL SHEETS IF NECESSARY

O-627