WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20566
Permit No. 36053
Basin 083 085

1. OWNER Gordon Harris ADDRESS Spanish Springs

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 21 N/S R. 20 E. Washoe County
PERMIT NO. STATE # 20265

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐
(Public)

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Loose Sand		0	25	25
Coarse Multi Col Dk w/ Some Volc. Chips		25	175	150
Fine Granite w/ Multi Col Sands		175	202+	27+
Fluid Level @ 122 FT				
Tested Well with Pump				
Well Pumped Off in 12				
Minutes. Well Would Recover				
To 122' Static Level.				
Well Recovery Rate @ 1.25				
GPM				

Date started 10-19, 19 79
Date completed 10-23, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailer @	1.25	4'	45 min.
Clean + Develop			
		76'	12 MINUTES

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10¾ to 50 & 8¾ to T.D. inches Total depth 202 feet
Casing record 6⅝ O.D.
Weight per foot ..... Thickness .156

Diameter	From	To
6⅝ O.D. inches	41 feet	202 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 202 feet

Perforations:
Type perforation Factory
Size perforation ⅛ x 3
From 162 feet to 202 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 122 Feet below land surface
Flow ..... G.P.M. .....
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service
Address 2255 Glendale Ave Sparks
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [illegible]
Date 10-24-79

USE ADDITIONAL SHEETS IF NECESSARY

O-627