WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 2010
Permit No.
Basin

1. OWNER STEVE ~~Yokum~~ Yochum ADDRESS 202 MARY ST MARK TWAIN
Lot 29 UNIT 1

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 17 N R. 22 E. STOREY County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large GRANITE Rocks		0	50'	50'
Red Clay		50'	60'	10'
White GRANITE		60'	90'	30'
Red Volcanic Rock		90'	290'	200'
WATER SAME AS ABOVE		290'	310'	20'

Date started 1-28-80, 19 80
Date completed 2-1-80, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 310 feet
Casing record 6 5/8" ~~[illegible]~~
Weight per foot 18.9 Thickness .156

Diameter		From		To	
6 5/8	inches	310	feet	0	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type 50' CEMENT
Depth of seal 50'
Gravel packed: Yes ☒ No ☐
Gravel packed from 310 feet to 260 feet

Perforations:
Type perforation FACTORY
Size perforation 16 X 32
From 310' feet to 290' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100' Feet below land surface
Flow 28 G.P.M.
Water temperature 65 °F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE
Address 2255 GLENDALE SPARKS
Nevada contractor's license number 15291
Nevada driller's license number 1167
Signed Leslie M. Williams
Date 2-1-80

USE ADDITIONAL SHEETS IF NECESSARY