WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 20768
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER M & C Wrobleuski ADDRESS 1645 Elemwest Drive
Reno, Nv. 89503

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 32 N. N/S R. 34 E. MDB&M- Pershing County
PERMIT NO. N/A

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	5	5
Clay		5	68	63
Sandstone		68	88	20
Shale		88	110	22
Clay		110	150	40
Shale		150	160	10
Clay		160	260	100
Sand, Gravel & clay		260	300	40

Date started March 3, 1980
Date completed March 6, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 300 feet
Casing record 6 5/8
Weight per foot 9.74 Thickness 10ga

Diameter	From	To
6 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 300 feet

Perforations:
Type perforation Sawed
Size perforation 1/8 Standard
From 140 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature Cold °F. Quality Good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Armstrong Brothers Well Drilling
Address 4710 HWY 40 West Winnemucca, Nv. 89445

Nevada contractor's license number 005348

Nevada driller's license number #619

Signed By: Armstrong Brothers Curtis Armstrong

Date March 7, 1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627