WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20792
Permit No.
Basin 108

1. OWNER PAT PEEPLES ADDRESS Hy. 95 #141 N. YERINGTON NEV.

2. LOCATION NE ¼ NE ¼ Sec. 16 T. 14 N/S R. 25 E. LYON County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COARSE SAND		0	15	15
CLAY		15	22	7
COARSE SAND + CLAY		22	35	13
FINE + COARSE SAND		35	50	15
COARSE SAND		50	70	20
CLAY		70	80	10
CLAY + COARSE SAND	X	80	90	10
COARSE SAND + GRAVEL	X	90	105	15

Date started 3-12, 19 80
Date completed 3-15, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	56	4'	1 HR

BAILER TEST
G.P.M. 20 Draw down 2 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 106' 3" feet
Casing record
Weight per foot Thickness 156 / 188

Diameter	From	To
6 5/8" inches	(+) 18' feet	104' 9" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 104' 9" feet

Perforations:
Type perforation SLOTTED
Size perforation 3/32" x 3" x 6 ROWS
From 84' 9" feet to 104' 9" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 11' 6" Feet below land surface 10'
Flow G.P.M.
Water temperature COLD° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name OGDEN BROS' DRILLING
Address 162 N. BYIBEE LN. YERINGTON, NEV. 89447

Nevada contractor's license number 15646

Nevada driller's license number 870

Signed Billy Ogden

Date 3/15/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627