WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

782-7166

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20834
Permit No.
Basin

1. OWNER Dick Sawtell ADDRESS 1495 Huntington Circle Reno

2. LOCATION ¼ ¼ Sec. 26 T. 19 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE Geo ☒
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Rock		1	35	
Gravel		36	47	
Clay Blue + Gray		48	132	
Blue Rock 100°		133	140	
Blue Clay		141	165	
Red Rock 120°		166	175	
Blue Clay + Shale		176	203	
Blue Clay		204	209	
Shale 145°		210	224	
Shale 155°		230	250	
Shale 160°		251	270	
Shale 165°		271	291	

Date started Dec 14, 19 78
Date completed Dec 16, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 291 feet
Casing record 1 to 291
Weight per foot Thickness 188

Diameter	From	To
8 inches	1 feet	184 feet
6 inches	180 feet	291 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type clean cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation factory
Size perforation 3/32
From 178 feet to 181 feet
From 271 feet to 291 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature 165 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kawchack Pump & Well Inc
Address Box 536 Cardnaville
Nevada contractor's license number #9511A
Nevada driller's license number 933
Signed Patrick W. Kenny
Date Dec 16, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471