WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20925
Permit No. 38904
Basin Washoe Valley

1. OWNER L.D.S. CHURCH ADDRESS
Parcel 1 - Parcel map 1073 - 26/3/80

2. LOCATION ~~NE~~ SW ¼ NE ¼ Sec. 32 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. 1151 38904

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSAND (BRN)		0	32	32
FINE DG (multi col)		32	51	19
FRACTURED GRANITE w/ STICKY CLAY		51	82	31
HARD GRANITE w/SOME FRACTURES	X	82	177	
SOFT BRN CLAY w/SOME SAND & GRANITE		177	190	
HARD GRANITE (BLK & WHITE)		190	352	
SEMI DECOMPOSED GRANITE w/SAND (multi Col.)	X	352	375+	

Date started 3-20, 19 80
Date completed 3-26, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Blew @ 150 PSI for 45 min to clean + develop - 20-25 gpm -		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 to 215 inches, Total depth 375' feet
Casing record 8 5/8 OD TO 215' - 210-375 - 6 5/8 OD LINER
Weight per foot ..... Thickness .....

Diameter	From	To
8 5/8 OD inches	H feet	215 feet
6 5/8 OD LINER inches	210 feet	375' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 215 feet

Perforations:
Type perforation FACTORY
Size perforation 1/8 X 3
From 175 feet to 215 feet
From 355 feet to 375 feet
From 325 feet to 345 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 150' Feet below land surface
Flow ..... G.P.M. 20-25
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA Drilling & Well Service
Address 2255 Glendale Ave
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [signature]
Date 4-5-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627

I

1980 APR 10 AM 10 10

OFFICE
STATE ENGINEER

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20925
Permit No. 38904
Basin Washoe Valley

1. OWNER L.D.S. CHURCH ADDRESS Parcel 1 - Parcel map 1073 - 26/3/80

2. LOCATION ~~NE~~ SW ¼ NE ¼ Sec. 32 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. 1151 38904

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSAND (BRN)		0	32	32
FINE DG (multi col)		32	51	19
FRACTURED GRANITE w/ STICKY CLAY		51	82	31
HARD GRANITE w/ SOME FRACTURES	X	82	177	
SOFT BRN CLAY w/ SOME SAND & GRANITE		177	190	
HARD GRANITE (BLK & WHITE)		190	352	
SEMI DECOMPOSED GRANITE w/ SAND (multi col)	X	352	375+	

Date started 3-20, 19 80
Date completed 3-26, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Blew @ 150 PSI for 45 min to clean & develop - 20-25 gpm -		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 to 215 inches, Total depth 375 feet
Casing record 8 5/8 OD TO 215 - 210-375 - 6 5/8 OD LINER
Weight per foot ..... Thickness .....

Diameter	From	To
8 5/8 OD inches	+1 feet	215 feet
6 5/8 OD LINER inches	210 feet	375 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 215 feet

Perforations:
Type perforation FACTORY
Size perforation 1/8 X 3
From 175 feet to 215 feet
From 355 feet to 375 feet
From 325 feet to 345 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 150' Feet below land surface
Flow ..... G.P.M. 20-25
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service
Address 2255 Glendale Ave
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [signature]
Date 4-5-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627