WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20929
Permit No.
Basin 103

1. OWNER BERNARD SMITH ADDRESS SPENCE LN. YERINGTON, NEV. 89447

2. LOCATION NW ¼ SE ¼ Sec. 8 T. 13 N/S R. 26 E. LYON County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND - TOP SOIL		0	2	2
CLAY		2	12	10
FINE + COARSE SAND		12	30	18
COARSE SAND		38	45	7
CLAY + COARSE SAND		45	60	15
FINE SAND		60	65	5
CLAY		65	70	5
COARSE SAND + GRAVEL	X	70	100	30

Date started 3-20, 1980
Date completed 3-25, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	30	4'	2HR.

BAILER TEST
G.P.M. 15 Draw down 2 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 100' feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	(+) 1 feet	99 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 99' feet

Perforations:
Type perforation SAWED
Size perforation 3/32" x 3" x 6 ROWS
From 78' feet to 99' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 14' Feet below land surface 13
Flow — G.P.M. —
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name OGDEN BROS' DRILLING
Address 162 N. BYBEE LN. YERINGTON, NEV. 89447

Nevada contractor's license number 15646

Nevada driller's license number 870

Signed Billy Ogden

Date 3/31/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627