

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Sailey Brothers Ranch ADDRESS Starr Valley  
 2. LOCATION NE 1/4 NW 1/4 Sec 6 T. 37 N/S R. 63 E. Elba County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Fin

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand (gravel)</u>		<u>0</u>	<u>3</u>	
<u>Dirty coarse gravel</u>		<u>3</u>	<u>310</u>	
<u>conglomerate with sandstone &amp; limestone</u>		<u>310</u>	<u>370</u>	
<u>Red &amp; Orange limestone</u>		<u>370</u>	<u>375</u>	<u>1 gpm</u>
<u>Harder conglomerate</u>		<u>375</u>	<u>445</u>	
<u>Grey limestone</u>		<u>445</u>	<u>460</u>	
<u>Grey limestone thin quartz</u>		<u>460</u>	<u>562</u>	
<u>Grey limestone with white ferruginous line fractured</u>		<u>562</u>	<u>—</u>	
<u>Could submersible pump set on 1 1/2" steel pipe to 441 ft</u>				

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 575 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 250  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>575</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory drilled  
 Size perforation 1/2" x 3  
 From 555 feet to 575 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Dec 15 1979  
 Date completed Feb 15 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 15 Draw down 20 feet 5 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 267 Feet below land surface 267  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature coll ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name R.D. Reynolds Drilling  
 Address Walla, Wa.  
 Nevada contractor's license number 014410  
 Nevada driller's license number 776  
 Signed [Signature]  
 Date 4/16/80